

Flame temperature	Given by the 125 mm / 500 W test flame The flame has to be calibrated as specified in ASTM D 5207-91
Burner type	Laboratory burner (Tirrill burner), as specified in ASTM D 5025-94
Sample position and Length	Vertical / 450 mm
Flame duration	3 cycles, each cycle 60 sec. with a break of 30 sec.
Conditions	The cable shall not convey flame either during or after the 3 cycles and no burning particles shall fall from the cable.

